

DOCUMENT NO.: KP1/13D /4/1/TSP/11/012-1



Kenya Power

**245kV SF₆ CIRCUIT BREAKERS WITH SINGLE POLE OPERATING MECHANISM -
SPECIFICATION**

A Document of the Kenya Power & Lighting Co. Plc.

March 2021



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 2 of 23	

TABLE OF CONTENTS

0.1	CIRCULATION LIST	3
0.2	AMENDMENT RECORD.....	4
	FOREWORD	5
1.	SCOPE	6
2.	NORMATIVE REFERENCES	6
3.	DEFINITIONS AND ABBREVIATIONS.....	6
3.1.	ABBREVIATIONS.....	6
4.	REQUIREMENTS.....	7
4.1.	SERVICE CONDITIONS	7
4.2.	DESIGN AND CONSTRUCTION	7
4.2.1	GENERAL.....	7
4.2.2	OPERATING MECHANISM	9
4.2.3	RATINGS	11
5	TESTS REQUIREMENTS.....	12
6	MARKING AND PACKING	12
6.1	MARKING	12
6.2	PACKING	13
6.3	MANUFACTURER'S EXPERIENCE AND CAPACITY	13
	APPENDICES	13
A:	TESTS AND INSPECTION (Normative).....	13
B:	QUALITY MANAGEMENT SYSTEM (Normative).....	15
C:	DOCUMENTATION (Normative).....	15
D:	GUARANTEED TECHNICAL PARTICULARS (Normative)	17

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-03-16

Authorized by: Head of Department, Standards

Signed:

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 3 of 23	

0.1 CIRCULATION LIST



COPY NO.	COPY HOLDER
1	Manager, Standards
2	Electronic copy (pdf) on Kenya Power server (http://172.16.1.40/dms/browse.php?fFolderId=23)

REVISION OF KPLC STANDARDS

In order to keep abreast of progress in the industry, KPLC standards shall be regularly reviewed. Suggestions for improvements to approved standards, addressed to the Manager, Standards Department, are welcome.

© Kenya Power & Lighting Co. Plc.

Users are reminded that by virtue of Section 25 of the Copyright Act, 2001 (Revised 2009) Cap 130 of the Laws of Kenya copyright subsists in all KPLC Standards and except as provided under Section 26 of this Act, no KPLC Standard produced by KPLC may be reproduced, stored in retrieval system by any means without prior permission from the Managing Director & CEO, KPLC.


Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed: 	Signed: 
Date: 2021-03-16	Date: 2021-03-16




**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 4 of 23	

0.2 AMENDMENT RECORD

Rev No.	Date (YYYY-MM-DD)	Description of Change	Prepared by (Name & Signature)	Approved by (Name & Signature)
Issue 2, Rev 0	2021-03-16	Cancel and replaces all previous editions	Eng. J. Ndirangu	Dr. Eng. P. Kimemia 

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-03-16

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 5 of 23	

FOREWORD

This Specification has been prepared by the Standards Department and Technical Services Department of The Kenya Power and Lighting Company Plc (KPLC) and it lays down requirements for 245kV SF₆ Circuit Breakers with single pole operating mechanism

The 245kV SF₆ Circuit Breakers with single pole operating mechanism are intended for use in the network for switching power transformers, short and long transmission lines and for fault current interruption.

Specifications in this series are:

- (i) KP1/6C/4/1/TSP/11/004-1: 145kV SF₆ Circuit Breakers with single pole operating mechanism -Specification
- (ii) KP1/6C/4/1/TSP/11/003: 72.5kV SF₆ Circuit Breakers with ganged three pole operating mechanism -Specification

This Specification stipulates the minimum requirements for 245kV SF₆ Circuit Breakers with single pole operating mechanism acceptable for use in the company and it shall be the responsibility of the suppliers and manufacturer to ensure that the offered design is of the highest quality and guarantees excellent service to KPLC, good workmanship and good engineering practice in the manufacture of the 245kV SF₆ Circuit Breakers with single pole operating mechanism for KPLC.

Users of this KPLC specification are responsible for its correct interpretation and application.

The following are members of the team that developed this specification:

Name	Department
Eng. Paul Mwangi	Technical Services
Eng. Kahoro Wachira	Technical Services
Eng. Julius Ndirangu	Standards

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 6 of 23	

1. SCOPE

This Specification covers the requirements, design, test methods, marking and packing of 245kV SF₆ Circuit Breakers with single pole operating mechanism complete with controls, support structures and ancillary equipment.

2. NORMATIVE REFERENCES

The following standards contain provisions which, through reference in this text, constitute provisions of this specification. For dated editions, the cited edition will apply; for undated editions, the latest edition of the referenced document shall apply.

IEC 62271-100: High Voltage Switchgear and Control gear - Part 100: High Voltage Alternating Current Circuit Breakers.

IEC 60376: Specification of technical grade sulfur hexafluoride (SF₆) for use in electrical equipment.

IEC/ISO 17025: General requirements for the competence of testing and calibration laboratories

ISO 1461: Hot dip galvanized coatings on fabricated iron and steel articles — Specifications and test methods.

IEC 60529: Degrees of protection provided by enclosures (IP Code).

BS1363: 13A plugs socket-outlets adaptors and connections units.

3. DEFINITIONS AND ABBREVIATIONS

For the purpose of this specification, the definitions and abbreviations given in the reference standards shall apply together with the following:

3.1. ABBREVIATIONS

KPLC- Kenya Power and Lighting Company Plc.

IEC – International Electro Technical Commission

ISO – International Organization for Standardization.

ISO 9001: 2015 - Quality Management Systems - Requirements

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2021-03-16

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 7 of 23	

4. REQUIREMENTS

4.1. SERVICE CONDITIONS

4.1.1 The 245kV SF₆ Circuit Breakers with single pole operating mechanism shall be suitable for continuous use outdoors in tropical areas with the following conditions:

- a. Altitudes of up to 2200m above sea level;
- b. Humidity of up to 95%;
- c. Average ambient temperature of +30°C with a minimum of -1°C and a maximum of +40°C
- d. Pollution: Design pollution level to be taken as “Heavy” (Pollution level III) for inland and “Very Heavy” (Pollution level IV) for coastal applications.
- e. Isokeraunic levels of up to 180 thunderstorm days per year.

4.1.2 The circuit breaker shall be installed in an effectively (solidly) earthed system

4.2. DESIGN AND CONSTRUCTION

4.2.1 GENERAL

4.2.1.1 The 245kV SF₆ Circuit Breakers with single pole operating mechanism shall be of single pole mechanism type for each phase, out-door type, SF₆ gas insulated and shall comply with the requirements of IEC 62271-100 and the requirements of this specification.

4.2.1.2 The circuit breakers shall be of live tank type.

4.2.1.3 Each pole shall have separate SF₆ gas system each with a gas pressure monitor.

4.2.1.4 Each of the circuit breaker poles shall be operated by local electrical and remote electrical controls from the local central circuit breaker control cabinet and the remote control panel respectively.

4.2.1.5 The circuit breaker shall have SF₆ gas as medium for electrical interruption and insulation.

4.2.1.6 The SF₆ gas shall comply with the requirement of IEC 60376 and be suitable for use in the circuit breaker when it is operated under the service and system conditions specified. The normal leakage rate of SF₆ shall not exceed 0.5% per year.

4.2.1.7 Sufficient gas shall be provided for filling the circuit breaker at installation with additional 20% for any losses.

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16




**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 8 of 23	

- 4.2.1.8 Circuit Breaker SF₆ gas filling accessories including regulator, male and female connectors and gate valve and any other special accessory required for gas evacuation and filling shall be provided. One set for each complete breaker.
- 4.2.1.9 When the circuit breaker is in closed position a rapid fall in the SF₆ gas pressure, to a level below that at which safe operation is possible shall not result in tripping the circuit breaker, but lockout of the circuit breaking preventing any electrical open or close operation. A remote alarm indication to signal circuit breaker lockout condition shall be provided.
- 4.2.1.10 An alarm stage for SF₆ leakage shall also be provided to indicate moderate fall in gas pressure, though in this state the circuit breaker shall be safe to operate.
- 4.2.1.11 Insulation creepage distance shall not be less than 31mm per kV of rated voltage between phases.
- 4.2.1.12 Each pole of the circuit breaker shall be equipped with a trip counter operated by the circuit breaker mechanism.
- 4.2.1.13 A pole discrepancy scheme shall be implemented in the central control cubicle. The pole discrepancy timer shall have adjustable time delay of at least 0 to 5 seconds. The operation of the pole discrepancy will result in three phase trip & lock out of the circuit breaker. A reset will be required to be able to close the circuit breaker. A visual indication will be provided to signal operation of the pole discrepancy scheme, as well as contacts for remote indication.
- 4.2.1.14 Three galvanized column steel support structures shall be supplied with the circuit breaker, one for each pole. All the bolts, nuts and fasteners for connecting the circuit breaker pole onto the support structure shall be provided. All ferrous parts shall be galvanized as per ISO 1461.
- 4.2.1.15 The resistance of the circuit breaker primary circuit (contact resistance) shall not exceed the values specified in IEC 62271-100.
- 4.2.1.16 The circuit breaker shall be capable of 2000 mechanical operations.
- 4.2.1.17 One trip coil and one closing coil shall be supplied as mandatory spares for each circuit breaker free of cost.

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-03-16

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 9 of 23	

4.2.2 OPERATING MECHANISM

- 4.2.2.1 The operating mechanism shall be suitable for mounting at the circuit breaker supporting structure, and below the circuit breaker in a weather-proof, dust-proof, vermin-proof and well ventilated housing. The degree of protection shall be at least IP 54 as per IEC 60529.
- 4.2.2.2 The operating mechanism shall open and close the circuit breaker within the specified opening and closing time of the circuit breaker and in any case, the opening times will be ≤ 50 ms and the closing time will be ≤ 100 ms, on average.
- 4.2.2.3 The operating mechanism shall after charging, carry out an Open-Close-Open (O-0.3s-CO) sequence with no external power supply to the operating mechanism.
- 4.2.2.4 The circuit breaker shall after a closing operation always be able to trip immediately without intentional time delay.
- 4.2.2.5 Operating mechanism shall be trip free during the entire closing sequence.
- 4.2.2.6 Operating mechanism shall be provided with motor wound spring actuated mechanism with provision for hand charge.
- 4.2.2.7 Motor operating voltage shall be 110 Volts d.c.
- 4.2.2.8 The operating mechanism shall be at ground potential, and shall house the secondary wiring for interface of the circuit breaker with the networks control and protection system.
- 4.2.2.9 A set of at least fifteen normally closed and fifteen normally open spare potential free contacts shall be provided for remote electrical indication as well as electrical interlocking and shall be wired to a terminal block in the housing.
- 4.2.2.10 A minimum of twenty (20) spare terminals shall be provided.
- 4.2.2.11 The circuit breaker shall be provided with Local/Remote selector switch. The selection of local operation shall inhibit the operation of the circuit breaker from any remote source. A spare contact for Local selection and Remote selection shall be provided on the switch for remote indications.
- 4.2.2.12 The circuit breaker shall be provided with a local switch for Open/Neutral/Close Operation. The position for Open, Neutral and close positions shall be clearly indicated on the switch.

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16




**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 10 of 23	

- 4.2.2.13 Mechanically operated indication to show the status of the circuit breaker position (open/close and springs charged/discharged) shall be provided. "ON" or "I", shall be used for CB closed status and "OFF" or "O" for CB open status.
- 4.2.2.14 The circuit breaker shall be provided with suitable terminals for connecting clamps for up to 3" outside diameter copper tubes.
- 4.2.2.15 The circuit breaker shall be provided with means to prevent contact pumping while the closing circuit remains energized, should the circuit breaker either fail to latch or be tripped during closing due to operation of the protective relays.
- 4.2.2.16 The circuit breaker shall be provided with duplicate trip coils and duplicate closing coils in order to facilitate duplication of protection tripping, where required.
- 4.2.2.17 The circuit breaker shall have separate operating mechanism for each pole, to allow circuit breaker single pole trip and automatic re-closure by protection and control scheme.
- 4.2.2.18 Each circuit breaker pole mechanism shall be provided with mechanical open/close operating links for circuit breaker pole maintenance. A clear warning notice should be provided next to the mechanical links, against operating the mechanical links when the SF₆ gas pressure is outside the safe operating levels.
- 4.2.2.19 The circuit breaker shall have a central control cabinet where the circuit breaker local three phase electrical close & open operations are carried out. This central control cabinet will be separate and independent from the circuit Breaker mechanism boxes. It shall be erected separately from the circuit breaker mechanism. All cabling to the circuit breaker mechanism boxes and to the protection and control cubicles shall be terminated at the central control cubicle.
- 4.2.2.20 An anti-condensation heater of adequate design and with suitable hygrostat and temperature controls shall be provided in the circuit breaker mechanism operating boxes and also in the central control cabinet, to prevent condensation. The anti-condensation heater shall be adequately rated and located in a position that ensure safety of personnel and effectiveness in keeping the whole cubicle dry to prevent condensation. It shall not cause deterioration in the wiring or in operation of the components.

Issued by: Head of Section, Standards Development

Signed: 

Date: 2021-03-16

Authorized by: Head of Department, Standards

Signed: 

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 11 of 23	

4.2.2.21 A cable plate shall be provided at the bottom of the circuit breaker mechanism box and central control cubicle. The cable plates shall be factory drilled, but blocked with removable stoppers to ensure integrity of IP degree of enclosure for the mechanism box and central control cabinet. The stoppers shall be easily knocked off at site. These shall be shown in the detailed drawings for approval.

4.2.2.22 The central control cubicle shall have a door operated LED lighting.

4.2.2.23 Each mechanism box shall be fitted with suitable lifting lugs for ease of lifting and assembly of the circuit breaker. The central control cubicle shall also be fitted with suitable lifting lugs.

4.2.2.24 Each of the three single phase mechanism boxes for each three phase circuit breaker shall be clearly labelled with letters R, Y & B in indelible marking to identify the phases and the labels shall be readily visible from the ground.

4.2.2.25 The central control cabinet shall be fitted with a 230 \pm 10%V AC socket outlet with three square terminals (Live, Neutral & Ground) as per BS 1363 standard. The 230 \pm 10%V AC Outlet will be controlled by an embedded ON/OFF switch.

4.2.2.26 All terminal blocks used inside the operating mechanism box and in the central control cabinet, shall as a minimum comply with IP20 degree on enclosure to ensure adequate personnel safety.

4.2.2.27 Wiring of the mechanism box and the central control cubicle shall be done in 2.5 mm² stranded and flexible copper conductors. All wiring connections to the terminal block will be lugged and labelled using ferrules. The terminal blocks shall be indelibly marked with numbers.


4.2.2.28 Painting of the mechanism boxes and the central control cubicles shall be such that the paint work shall not wear due to weather conditions and ultra violet radiation during the duration of service.


4.2.3 RATINGS

4.2.3.1 The guaranteed operating characteristics of the 245kV SF₆ Circuit Breakers with single pole operating mechanism shall be complied with during tests, with all the features stated in Table 1.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-03-16

Date: 2021-03-16

Table 1: Ratings for 245 kV SF₆ Circuit Breakers

Item	Parameters, Units	Value
1.	Rated Voltage, kV	245
2.	Frequency, Hz	50
3.	Normal Current, A	3150
4.	Rated short circuit current, kA	40
5.	Duration of short circuit, sec	3
6.	Rated short circuit making current, kA	100
7.	First pole to clear factor	1.5
8.	Operating sequence	0-0.3 sec – CO – 3 min - CO
9.	Auxiliary D.C Voltage for closing & tripping coils, Vdc	110
10	Auxiliary A.C Voltage and frequency V, Hz	400/230±10%, 50
11	Lightning Impulse withstand voltage, kV peak	1050
12	One minute power frequency withstand voltage, kV r.m.s.	460
13	Creepage distance of insulator, mm	7595
14	Minimum clearance between phases, mm	3100
15	Minimum clearance to earth, mm	2100
16	Temperature Class of Circuit Breaker	-5°C to +50°C

5 TESTS REQUIREMENTS

The 245kV SF₆ Circuit Breakers with single pole operating mechanism shall be inspected and tested in accordance with the requirements of IEC 62271-100 and this specification.


6 MARKING AND PACKING

6.1 MARKING

The nameplates of the circuit breaker and its operating devices shall be marked in accordance with clause 5.10 of IEC 62271-100 in English language. All markings shall be indelible and legible. Nameplate and their fixings shall be weatherproof and corrosion proof.

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-03-16

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 13 of 23	

6.2 PACKING

- 6.2.1 245kV SF₆ Circuit Breakers with single pole operating mechanism shall be packaged for outdoor storage in tropical conditions defined in clause 4.1.
- 6.2.2 A set of five (5) Original Hard Cover Installation, Operation and Maintenance Manuals for the circuit breakers shall be supplied with each complete breaker.
- 6.2.3 Recommendations for use, care, storage and routine inspection/testing procedures, all in English language shall be submitted.

6.3 MANUFACTURER'S EXPERIENCE AND CAPACITY

- 6.3.1 The circuit breaker manufacturer shall have a minimum of 25 years' experience in the manufacture of 245kV SF₆ circuit Breakers with single pole operating mechanism.
- 6.3.2 The circuit breaker on offer shall have been in service and given reliable service for a minimum period of 8 years in at least two (2) power utilities in at least three (3) of the following continents/regions:
- Europe
 - North America
 - Africa
 - Asia or South America

The manufacturer shall provide references to support requirements of this including export records with copy of contractual letters, circuit breaker details and date of sale/export, letter of satisfaction from power utilities.

- 6.3.3 Circuit breakers brands that have failed in service or mal-operated while in service on the Kenyan power system shall not be accepted.
- 6.3.4 The warranty for the offered circuit breaker shall be 5 years from the date of circuit breaker delivery to KPLC store.

APPENDICES

A: TESTS AND INSPECTION (Normative)

- A.1 It shall be the responsibility of the supplier to test or to have all the relevant tests performed.
- A.2 Copies of Type Test Certificates and Type Test Reports for 245kV SF₆ circuit Breakers with single pole operating mechanism issued by a third party testing laboratory that is accredited to ISO/IEC 17025 and shall be submitted with the tender for the purpose of technical evaluation. A copy of

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 14 of 23	



the accreditation certificate for the testing laboratory shall also be submitted with the tender (all in English Language).

Copies of type test reports to be submitted with the tender for evaluation shall include the following tests in accordance with IEC 62271-100:

- a. Dielectric tests
- b. Radio interference voltage tests
- c. Measurement of the resistance of the main circuit
- d. Temperature-rise tests
- e. Short-time withstand current and peak withstand current tests
- f. Tightness tests
- g. EMC tests
- h. Mechanical operation test at ambient temperature
- i. Short-circuit current making and breaking tests
- j. Capacitive current switching tests: line-charging current breaking tests
- k. Verification of degree of protection
- l. Humidity test

NOTE: Any translations of certificates and test reports into English language shall be signed and stamped by the Testing Authority.

- A.3 Routine and sample test reports for the 245kV SF₆ circuit breakers with single pole operating mechanism to be supplied shall be submitted to KPLC before delivery. KPLC Engineers will witness tests at the factory before delivery. Tests to be witnessed by KPLC Engineers at the factory before delivery shall be in accordance with IEC 62271-100 and this specification and shall include the following:
- a) Dielectric test on main circuit
 - b) Dielectric test on auxiliary and control circuits
 - c) Measurement of the resistance of the main circuit
 - d) Tightness test
 - e) Design and visual checks
 - f) Mechanical operating tests
- A.4 Training on Installation and Maintenance: - The Manufacturer shall conduct Virtual Training on Installation, Testing and Maintenance of the Circuit Breaker to Ten (10) Kenya Power Engineers & Technicians. Maintenance shall cover both the operating mechanism and the interruption chamber.
- A.5 On receipt of the 245kV SF₆ circuit Breakers with single pole operating mechanism, KPLC will inspect them and may perform any of the relevant tests in order to verify compliance with the specification. The supplier shall replace without charge to KPLC, any 245kV SF₆ circuit Breakers

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed: 	Signed: 
Date: 2021-03-16	Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 15 of 23	

with single pole operating mechanism which upon examination, test or use fail to meet any or all of the requirements in the specification.

B: QUALITY MANAGEMENT SYSTEM (Normative)

B.1 The supplier shall submit a quality assurance plan (QAP) that will be used to ensure that the 245kV SF₆ circuit Breakers with single pole operating mechanism physical properties, tests and documentation, will fulfill the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfill the requirements of ISO 9001.

B.2 The Manufacturer's Declaration of Conformity to applicable standards and copies of quality management certifications including copy of valid and relevant ISO 9001 certificate shall be submitted with the tender for evaluation.

C: DOCUMENTATION (Normative)

C.1 The bidder shall submit its tender complete with technical documents for tender evaluation. The technical documents to be submitted (all in English language) for tender evaluation shall include the following:

- a) Fully filled clause by clause guaranteed technical particulars (GTP) signed and stamped by the manufacturer;
- b) Copies of the Manufacturer's catalogues, brochures, drawings giving all relevant dimensions and technical data;
- c) References letters to support requirements of clause 6.3.2 including export records with copy of contractual letters, circuit breaker details and date of sale/export, letter of satisfaction from power utilities.
- d) Details of manufacturing capacity.
- e) Copies of required type test reports by a third party testing laboratory accredited to ISO/IEC 17025.
- f) Copy of accreditation certificate to ISO/IEC 17025 for the third party testing laboratory;
- g) Contacts and address of third party testing laboratory;

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed:

Signed:

Date: 2021-03-16

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 16 of 23	

h) Manufacturers letter of authorization, ISO 9001 certificate and other technical documents required in the tender.

C.2 The successful bidder (supplier) shall submit the following documents/details to The Kenya Power & Lighting Company Plc for approval before manufacture:

- a) Fully filled clause by clause guaranteed technical particulars (GTP) stamped and signed by the manufacturer (these are not the ones submitted with the tender) ;
- b) Design Drawings with details of the 245kV SF₆ circuit Breakers with single pole operating mechanism to be manufactured for KPLC;
- c) Detailed Design Drawings with dimensions to be used for manufacture of the 245kV SF₆ circuit Breakers with single pole operating mechanism for KPLC;
- d) Quality assurance plan (QAP) that will be used to ensure that the design, material; workmanship, tests, service capability, maintenance and documentation will fulfill the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfill the requirements of ISO 9001;
- e) Marking details and method to be used in marking the 245kV SF₆ circuit Breakers with single pole operating mechanism
- f) Packaging details including packaging materials.
- g) Product samples (where applicable).

C.3 Statement of compliance to specification (indicate deviations if any provide supporting documents)

NOTE: *The drawings to be submitted by the supplier to KPLC for approval before manufacture shall be in standard format clearly indicating the drawing number, parts list with material details and quantities, standard of manufacture, ratings, approval details and identity of the manufacturer (as per manufacturer's authorization submitted during tendering).*

Issued by: Head of Section, Standards Development

Signed:

Date: 2021-03-16

Authorized by: Head of Department, Standards

Signed:

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 17 of 23	

D: GUARANTEED TECHNICAL PARTICULARS (Normative)

To be filled and signed by the Manufacturer and submitted together with relevant copies of the Manufacturer's catalogues, brochures, drawings, technical data, sales records for previous five years, four customer reference letters, details of suppliers' capacity and experience; and copies of complete type test certificates and test reports for tender evaluation, all in English Language)

Tender No.

Bidder's name and Address.....


Clause number	KPLC Requirements	Bidder's offer
	Manufacturer's Name and address	Specify
	Country of Manufacture	Specify
	Name and model Number	Specify
1.	Scope	State
2.	Normative References	State
3.	Definitions and Abbreviations	
3.1.	Abbreviations	State
4.	Requirements	
4.1.1	Service conditions	State
4.1.2	CB shall be installed in an effectively(Solidly) earthed system	State
4.2	Design and Construction	
4.2.1	General	
4.2.1.1	With Single pole Operating mechanism type for each phase, out-door type, SF ₆ gas insulated	State
	Comply with IEC 62271-100 and KPLC specification	State
4.2.1.2	Circuit breakers shall be of live tank type	State
4.2.1.3	Each pole shall have separate SF ₆ gas system each with a gas pressure monitor	State
4.2.1.4	Each of the circuit breaker poles shall be operated by local electrical and remote electrical controls from the local central circuit breaker control cabinet and the remote control panel respectively.	State
4.2.1.5	circuit breaker shall have SF ₆ gas as medium for electrical interruption and insulation	State
4.2.1.6	SF ₆ gas shall comply with the requirement of IEC 60376	State
	Normal leakage rate of SF ₆ shall not exceed 0.5% per year	State
4.2.1.7	Sufficient gas shall be provided for filling the circuit breaker at installation with additional 20% for any losses	State


Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16

Clause number	KPLC Requirements	Bidder's offer
4.2.1.8	SF ₆ gas filling accessories including regulator, male and female connectors and gate valve and any other special accessory required for gas evacuation and filling shall be provided. One set for each complete breaker	Provide
4.2.1.9	When the circuit breaker is in closed position a rapid fall in the SF ₆ gas pressure, to a level below that at which safe operation is possible shall not result in tripping the circuit breaker, but lockout of the circuit breaking preventing any electrical open or close operation	State
	Remote alarm indication to signal circuit Breaker lockout condition shall be provided.	State
4.2.1.10	Alarm stage for SF ₆ leakage shall also be provided to indicate moderate fall in gas pressure	State
	In this state the circuit breaker shall be safe to operate	State
4.2.1.11	Insulation creepage distance	State
4.2.1.12	Each pole of the circuit breaker shall be equipped with a trip counter operated by the circuit breaker mechanism	State
4.2.1.13	A pole discrepancy scheme shall be implemented in the central control cubicle	State
	Pole discrepancy timer shall have adjustable time delay of at least 0 to 5 seconds	State
	Operation of the pole discrepancy will result in three phase trip & lock out of the circuit breaker. A reset will be required to be able to close the circuit breaker	State
	A visual indication will be provided to signal operation of the pole discrepancy scheme, as well as contacts for remote indication	State
4.2.1.14	Three galvanized column steel support structures shall be supplied with the circuit breaker, one for each pole.	Provide
	All the bolts, nuts and fasteners for connecting the circuit breaker pole onto the support structure shall be provided.	State
4.2.1.15	The resistance of the circuit breaker primary circuit (contact resistance) shall not exceed the values specified in IEC 62271-100	State
4.2.1.16	The circuit breaker shall be capable of 2000 mechanical operations.	State
4.2.1.17	One trip coil and one closing coil shall be supplied as mandatory spares for each circuit breaker free of cost.	Provide
4.2.2	Operating Mechanism	
4.2.2.1	Suitable for mounting at the circuit breaker supporting structure, and below the circuit breaker in a weather-proof, dust-proof, vermin-proof and well ventilated housing	State
	Degree of protection shall be at least IP 54 as per IEC 60529	State

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-03-16

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 19 of 23	

Clause number	KPLC Requirements	Bidder's offer
4.2.2.2	Shall open and close the circuit breaker within the specified opening and closing time of the circuit breaker. opening times will be ≤ 50 ms and the closing time will be ≤ 100 ms	State
4.2.2.3	Operating mechanism shall after charging, carry out an Open-Close-Open (O-0.3s-CO) sequence with no external power supply to the operating mechanism	State
4.2.2.4	After a closing operation CB shall always be able to trip immediately without intentional time delay	State
4.2.2.5	Operating mechanism shall be trip free during the entire closing sequence	State
4.2.2.6	Operating mechanism shall be provided with motor wound spring actuated mechanism with provision for hand charge	Provide
4.2.2.7	Motor operating voltage shall be 110 Volts d.c	State
4.2.2.8	Operating mechanism shall be at ground potential, and shall house the secondary wiring for interface of the circuit breaker with the networks control and protection system	State
4.2.2.9	At least fifteen normally closed and fifteen normally open spare potential free contacts provided wired to a terminal block in the housing	Provide
4.2.2.10	Minimum of twenty (20) spare terminals shall be provided	Provide
4.2.2.11	circuit breaker shall be provided Local/Remote selector switch	Provide
	Selection of local operation shall inhibit the operation of the circuit breaker from any remote source	State
	Spare contact for Local selection and Remote selection shall be provided on the switch for Remote Indications	Provide
4.2.2.12	Local switch for Open/Neutral/Close Operation	Provide
	Position for Open, Neutral and close positions shall be clearly indicated on the switch.	State
4.2.2.13	Mechanically operated indication to show the status of the circuit breaker position (open/close and springs charged/discharged) shall be provided	Provide
	"ON" or "I", shall be used for CB closed status and "OFF" or "O" for CB open status	State
4.2.2.14	Suitable terminals for connecting clamps for up to 3" outside diameter copper tubes	Provide
4.2.2.15	Means to prevent contact pumping while the closing circuit remains energized, should the circuit breaker either fail to latch or be tripped during closing due to operation of the protective relays	provide

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 20 of 23	

Clause number	KPLC Requirements	Bidder's offer
4.2.2.16	Duplicate trip coils and duplicate closing coils to facilitate duplication of protection tripping, where required	Provide
4.2.2.17	Separate operating mechanism for each pole, to allow circuit breaker single pole trip and automatic re-closure by protection & control scheme	Provide
4.2.2.18	Circuit breaker pole mechanism provided with mechanical open/close operating links for circuit breaker pole maintenance	Provide
	Clear warning notice should be provided next to the mechanical links, against operating the mechanical links when the SF ₆ gas pressure is outside the safe operating levels	Provide
4.2.2.19	Central control cabinet will be separate and independent from the circuit breaker mechanism boxes	Provide
	All cabling to the circuit breaker mechanism boxes and to the protection and control cubicles shall be terminated at the Central Control Cubicle.	State
4.2.2.20	Anti-condensation heater of adequate design with suitable hygostat and temperature controls shall be provided in the circuit breaker mechanism operating boxes and also in the central control cabinet	Provide
	The anti-condensation heater shall be adequately rated and located in a position that ensure safety of personnel and effectiveness in keeping the whole cubicle dry to prevent condensation	State
	It shall not cause deterioration in the wiring or in operation of the components.	State
4.2.2.21	Cable plate shall be provided at the bottom of the circuit breaker mechanism Box and Central Control Cubicle	Provide
	Cable plates shall be factory drilled, but blocked with removable stoppers, easily knocked off at site	State
4.2.2.22	Central control cubicle shall have a door operated LED lighting	Provide
4.2.2.23	Each mechanism box as well as the central control cubicle shall be fitted with suitable lifting lugs	Provide
4.2.2.24	Letters R, Y & B in indelible marking to identify the phases readily visible from the ground	Provide
4.2.2.25	230 \pm 10%V AC socket outlet with three square terminals (Live, Neutral & Ground) as per BS 1363 standard inside the central controlled cabinet	Provide
	The 230 \pm 10%V AC Outlet will be controlled by an embedded ON/OFF switch.	State
4.2.2.26	IP degree for terminal blocks inside the operating mechanism box and in the Central Control Cabinet.	State

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 21 of 23	


Clause number	KPLC Requirements	Bidder's offer
4.2.2.27	Wiring of the Mechanism Box and the central Control Cubicle shall be done in 2.5 mm ² stranded and flexible copper conductors	State
	All wiring connections to the terminal Block will be lugged and labelled using ferrules	State
	The terminal Blocks will be indelibly marked with numbers	State
4.2.2.28	Painting of the mechanism boxes and the central control cubicles shall be such that the paint work shall not wear due to weather conditions and ultra violet radiation during the duration of service	State
4.2.3	Ratings	
4.2.3.1	Rated Voltage, kV	State
	Frequency, Hz	State
	Normal Current, A	State
	Rated short circuit current, kA	State
	Duration of short circuit	State
	Rated short circuit making current	State
	First pole to clear factor	State
	Operating sequence	State
	Auxiliary D.C Voltage for closing & tripping coils	State
	Auxiliary A.C Voltage	State
	Lightning Impulse withstand voltage	State
	One minute power frequency withstand voltage	State
	Creepage distance of insulator	State
	Minimum clearance between phases	State
Minimum clearance to earth	State	
Temperature Class of Circuit Breaker	State	
5	Test Requirements	
	Test standard	State
6	Marking and Packing	
6.1	Details marked indelibly and legibly on nameplate	specify
	Nameplate and their fixings shall be weatherproof and corrosion proof.	State
6.2	Packing	
6.2.1	Shall be packaged for outdoor storage in tropical conditions defined in clause 4.1	State
6.2.2	Set of five (5) Original Hard Cover Installation, Operation and Maintenance Manuals for the circuit breakers shall be supplied with each complete breaker.	Provide

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16

Clause number	KPLC Requirements	Bidder's offer
6.2.3	Recommendations for use, care, storage and routine inspection/testing procedures, all in English language shall be submitted.	submit
6.3	Manufacturer's Experience and Capacity	
6.3.1	Minimum of 25 years' experience in the manufacture of 245kV SF ₆ circuit Breakers with single pole operating mechanism	State
6.3.2	Circuit breaker on offer have been in service and given reliable service for a minimum period of 8 years in at least two (2) power utilities in at least three (3) of the following continents/regions: i) Europe ii) North America iii) Africa iv) Asia or South America	Attach references
6.3.3	Circuit breakers failed in service or mal-operated while in service on the Kenyan power system	State
6.3.4	5 years warranty	State
A	Tests and Inspection	
A.1	Responsibility of the supplier to test or to have all the relevant tests performed	State
A.2	Copies of type test reports submitted for evaluation	list
A.3	Tests to be witnessed by KPLC Engineers at the factory	list
A.4	Manufacturer shall conduct Virtual Training on Installation, Testing and Maintenance of the Circuit Breaker to Ten (10) Kenya Power Engineers & Technicians. Maintenance shall cover both the operating mechanism and the interruption chamber.	State
A.5	Inspection at the stores and replacement of rejected items	State compliance
B	Quality Management System	
B.1	Quality Assurance Plan	Attach
B.2	Copy of ISO 9001:2015 Certificate	Attach
C	Documentation	
C.1	Documents submitted with tender for evaluation	List
C.2	Documents submitted for approval before manufacture	List
C.3	Statement of compliance to specification (indicate deviations if any & supporting documents)	State compliance

Issued by: Head of Section, Standards Development

Authorized by: Head of Department, Standards

Signed: 

Signed: 

Date: 2021-03-16

Date: 2021-03-16



**245kV SF₆ CIRCUIT
BREAKERS WITH
SINGLE POLE
OPERATING
MECHANISM -
SPECIFICATION**

Doc. No.	KP1/6C/4/1/TSP/11/012-1
Issue No.	2
Revision No.	0
Date of Issue	2021-03-16
Page 23 of 23	

NOTE:

1) Bidders shall give full details of the item(s) on offer as per the specification and applicable standards. The details provided shall conform to the test reports and their certificates, as well as labeled drawings complete with dimensions, catalogues and/or brochures for the purpose of tender evaluation.

2) Bidders should note that the above Guaranteed Technical Particulars Schedules must be fully completed and submitted with the bid. Wherever there is conflict between the GTPs and the clauses in the specification, the clauses in the specification take precedence. Failure to complete the schedules shall lead to rejection of the bid.

3) Guaranteed values shall be specified.

* Words like 'agreed', 'confirmed', 'As per KPLC specifications', Yes, etc. shall not be accepted and shall be considered non-responsive.

.....
Manufacturer's Name, Signature, Stamp and Date

Issued by: Head of Section, Standards Development	Authorized by: Head of Department, Standards
Signed:	Signed:
Date: 2021-03-16	Date: 2021-03-16

