



RURAL ELECTRIFICATION AND RENEWABLE ENERGY CORPORATION

CLARIFICATION 001

The following clarification was sort by a bidder for RFX: 1000001209-Tender for *Supply, Installation, Testing & Commissioning of Solar Powered High Mast Flood Lighting in Vihiga, Narok and Siaya Counties and clarified as follows;*

No	Technical Evaluation	Questions/Clarifications	Response
1	<i>Power tool for the winch (Procuring Entity's technical requirements)</i>	<i>Power tool for the winch if it should be electrical or manual in line with the below description; A suitable, high powered electrically driven internally mounted power tool with manual override, shall be supplied for the raising and lowering of the lantern carriage for maintenance purposes.</i>	<i>Power tool should be electrical</i>
2	<i>Power tool for the winch (Procuring Entity's technical requirements)</i>	<i>In case it is electrical, the provision of power source for the winch shall be catered by which entity</i>	<i>The bidder to cater for power source during testing, commissioning and final handover</i>
3	<i>Power tool for the winch (Procuring Entity's technical requirements)</i>	<i>Will the power source be permanent or temporal</i>	<i>Temporary</i>